

Addendum #1

Troup County Board of Commissioners

Fire Station #1 - RFP (8/21/2026)

Burkes Chapel Road & Whitesville Road, Troup County, Georgia

Sheet FS1.0 Add Note 5 to Fire Protection Shop Drawings and Submittals to read as follows:

5. Contractor shall provide an All-In-One NFPA 13D pump and tank system designed to meet the NFPA 13D requirements delivering the pressure and flow needed for a residential fire sprinkler system including a 325 gallon tank similar to H2home model number H2H325-E04 with a 1 ½ HP single phase 60HZ 240 volt pump motor, riser manifold kit, digital pressure switch unit tied to the domestic water entrance in Storage Room 122 including electrical hookups.

Add the same note to Sheets P1.2 and P1.3.

Coordinate new power on Sheets E2.0 and E2.1