

**Addendum 2**  
**Troup County Fire Station 14 Project**

**Questions and answers received on Fire Station 14 project:**

**Q:** Civil drawing Sheet 16 of 21 shows details for a 24" curb and gutter but the site plan on Sheet 5 of 21 does not show where the curb is to be place. Please confirm locations of curb & gutter.

**A:** Item #\_ Sheet A1.1 Floor Plan: Modify Keyed Construction Note # 21 to read "Coordinate exterior civil concrete sidewalks and concrete drives with Civil Documents - See Revised Sheet 5 of 21 Site Plan in the civil package. Note architectural sidewalks are 4" slabs per Site Details Sheet SP1.2, see civil plans for concrete drive profile".

Please see attached PDF

**Q:** Is there a qualification package needed for Troup County Fire Department #14?

**A:** No, there is not.

**Q:** Are the DOT redline drawings available?

**A:** We do not have any comments back from GDOT yet. We can't answer this question until we receive their comments.

**Q:** Is thermoplastic striping required on the DOT ROW?

**A:** We do not have any comments back from GDOT yet. We can't answer this question until we receive their comments.

**Q:** Is the prime coat in the asphalt paving detail required?

**A:** We do not have any comments back from GDOT yet. We can't answer this question until we receive their comments

**Q:**

The drawings provide conflicting information as to whether the signage scope is by owner or by GC. Keynote 5 on A1.1 states "signage by GC." The Interior Signage Schedule on A8.1 has two notes. One states, " Owner will provide all room signs - Contractor shall install." The second note says, "GC to provide signage submittal and shop drawings for owner and architect prior to order." Please clarify the signage scope for the bid.

**A:** Owner will provide and install all signage.

**Q:** Proposed Substitution: ABT's PolyDrain®

Address: Troutman, NC

Manufacturer: ABT, Inc.

Website: [www.abtdrains.com](http://www.abtdrains.com)

Trade Name: PolyDrain® Model Number: LA04-04.502E.WE-W51G

**A:** ABT PolyDrain Model Number: LA04-04.502E.WE-W51G as an acceptable alternate for Structural Trench Drain noted on Sheet A1.1, Keyed Construction Note 16.

